




Installation Instructions — EC-10VHL, #498188




To Remove the Baffle Filter



To Remove the Lights and Electrical Box



To Remove the Knob




Wiring Diagrams

Legend for Diagram	
English Terminology	Meaning
F	Fan Solid-State Speed Control
LT	Light
SSD	Light Solid-State Speed Control
Lo	Line Out Fan
Li	Line In
N	Neutral In


Note:

To connect power to the EC-10VHL, #498188, use a minimum of 16 American Wire Gauge (AWG), 3 core conductor cable, with a temperature rating of a minimum of 90° Celsius (190° Fahrenheit).

SSD Wiring




To Remove the Solid-State Fan Speed Control




To Remove the Solid-State Fan Speed Control Continued

Note:


Obey the local and national requirements for disposal.



To Mount the EC-10VHL, #498188




EC-10VHL, #498188




1. EC—10V, #498148 — Potentiometer
2. Blue – Ground/Common
3. Yellow – 0–10V Control/Potentiometer
4. Red (+) 10VDC

To Reinstall the Lights



To Reinstall the Baffle Filters



Fantech reserves the rights to alter their products without notice. This also applies to products already ordered, as long as it does not affect the previously agreed specifications.